

Monthly Operations Report

for the Municipality of Casselman's Water and
Wastewater Systems

November 2023



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Table of Contents

Section 1 - Monthly Operations Report Card

Section 2 - Facility Listing

Section 3 - Compliance

Section 4 - Facility Performance

Section 5 - Drinking Water Quality Management System (DWQMS)

Section 6 - Maintenance / Capital / Added Value

Section 7 - Complaints

Section 8 - Recommendations / General Comments

Appendices

Appendix A – Performance Assessment Reports

Appendix B – Work Order Summary Report

Appendix C – Locate Summary

A decorative graphic in the bottom right corner of the page. It features a light blue sun with a thick, curved arc at the top, and three wavy, horizontal bands below it, representing water or waves. The graphic is semi-transparent and blends into the white background.

SECTION 1 – MONTHLY OPERATIONS REPORT CARD

Operations and Compliance Reliability Indices

Legend					
✓	●	▲	✗	Y/N	N/A
Achieved	On Target	Caution	Not Achieved	Yes/No	Not Applicable

	Target	Current Month	Comments
Health & Safety			
Number of Incidents	0	●	
<i>Actual Result</i>		0	
Drinking Water			
Inspection Ratings (YTD)	100 %	●	
<i>Actual Result</i>		100 %	
AWQI's	0	●	
<i>Actual Result</i>		0	
Number of Non-Compliances	0	●	
<i>Actual Result</i>		0	
Number of Water Main Breaks	0	●	
<i>Actual Result</i>		0	
Number of Complaints	0	●	
<i>Actual Result</i>		0	
Water Main Flushing	0	●	
<i>Target Achieved</i>		Y	
Wastewater			
Number of Non-Compliances	0	●	
<i>Actual Result</i>		0	
Number of Bypasses	0	●	
<i>Actual Result</i>		0	
Number of Sanitary Sewer Back-ups	0	●	
<i>Actual Result</i>		0	
Sanitary Collection System Flushing	Y	●	
<i>Target Achieved</i>		Y	
Preventive Maintenance			
Work Orders Completed	>95%	●	
<i>Target Achieved</i>		Y	

SECTION 2 – FACILITY LISTING

Water Treatment & Distribution

Facility	Type
5971 - Casselman Water Treatment Plant	1 WTP (Actiflo Process)
1553 - Casselman Water Distribution System	1 Water Storage Tower + Water Distribution System

Wastewater Treatment & Collection

Facility	Type
1501 - Casselman Wastewater Treatment Plant	3 Facultative Lagoon Cells 1 MBBR (Moving Bed Biofilm Reactor)
5976 - Casselman Wastewater Collection System	6 Sewage Pumping Stations + Wastewater Collection System

SECTION 3 – COMPLIANCE

There were no compliance issues to report for Casselman’s water and wastewater treatment systems.

The most recent MECP inspections are listed below:

Location	Inspector	Inspection Rating (%)	Date
Casselman Water	Jean-Francois Durocher	100	February 9, 2023
Casselman Sewage	<i>*OCWA has no recent sewage system inspections on file.</i>		

There are no outstanding actions required from any recent MECP inspections.

SECTION 4 – FACILITY PERFORMANCE

Please see the Water & Wastewater Performance Assessment Reports attached in Appendix A.

SECTION 5 – DRINKING WATER QUALITY MANAGEMENT SYSTEM (DWQMS)

OCWA was re-accredited as the Operating Authority for Casselman’s Drinking Water System on January 24, 2023.

SECTION 6 - MAINTENANCE / CAPITAL / ADDED VALUE

Water Treatment & Distribution

- Responded to 9 after-hours call-in alarms
- Hach performed annual service and calibration of chemical analyzers at the WTP
- Water service turned on to units on Zachary Street
- Repaired standpost at 34 Desnoyers
- Observed water connection at 621A St. Isidore
- Repairs performed on heater in the UV room at the WTP
- Added extensions to Hydrants #23 & #25 on Principale
- Replaced hydrant body on Hydrant #30 located at Principale & Martin
- Repaired leaking hydrant #153 on Nature St.

Wastewater Treatment & Collection

- Responded to 1 after-hours call-in alarm due to power outage
- Hach performed annual service and calibration of equipment at the lagoon
- New Dissolved Oxygen sensors installed on MBBRs
- Annual maintenance performed on generators at SPS #2, #3 and #5
- Completed rebuild of Blower #3, serviced Blower #1
- Hydrocam in to flush sewer mains & clean wet wells at SPS #1, #5 and Cell #2 of MBBR
- Completed annual inspection of backflow preventers at SPS #1, SPS #6 and lagoon
- Lagoon discharge continued through November

Preventive Maintenance Plan (PMP) Work Order Summary

All required work orders were completed. Please refer to the summary reports attached in Appendix B.

SECTION 7 – COMPLAINTS

Facility	Date	Description
		None to report

SECTION 8 – RECOMMENDATIONS / GENERAL COMMENTS

General

- 45 locates were completed in November.

Water Treatment & Distribution

- Capital/Major Maintenance projects approved for 2023 continued through November.

Wastewater Treatment & Collection

- Capital/Major Maintenance projects approved for 2023 continued through November.
- Extra cleanings of the wet wells at SPS #1 and #6 have been required due to the accumulation of construction-related debris (soil/mud). Recommend to work with Engineers and developers to try to minimize debris entering into the sanitary system as a result of construction activities.

Appendix A

Performance Assessment Reports



ONTARIO CLEAN WATER AGENCY PERFORMANCE ASSESSMENT REPORT

MUNICIPALITY: MUNICIPALITY OF CASSELMAN
PROJECT: CASSELMAN DRINKING WATER SYSTEM
DESCRIPTION: SURFACE WATER TREATMENT PLANT
CHEMICALLY ASSISTED FILTRATION

YEAR: 2023
WATER SOURCE: NATION RIVER
DESIGN CAPACITY: 3182 m3/d
WORKS NUM.: 210001219

MONTH	SYSTEM FLOWS (TREATED)			TREATED		DISTRIBUTION		RAW					TREATED					DISTRIBUTION				
	Total Flow (m ³)	Avg. Flow (m ³)	Max Day Flow (m ³)	Min. Free Cl ₂ Resid. (mg/L)	Max Free Cl ₂ Resid. (mg/L)	Min Combined Cl ₂ Resid. (mg/L)	Max Combined Cl ₂ Resid. (mg/L)	Dissolved Organic Carbon (mg/L)	Total Organic Carbon (mg/L)	Total Hardness (mg/L)	Average Manganese (mg/L)	Max Manganese (mg/L)	IH Avg. Turbidity (NTU)	IH Max. Turbidity (NTU)	Dissolved Organic Carbon (mg/L)	Total Organic Carbon (mg/L)	Total Hardness (mg/L)	Average Manganese (mg/L)	Max Manganese (mg/L)	THM (µg/L) quarterly	HAA (µg/L) quarterly	NDMA (µg/L) quarterly
JAN	30,573	986	1259	1.10	2.49	1.00	2.26	8.30	8.40	242	0.12	0.20	0.22	0.33	3.00	3.20	224	0.07	0.18	53.75	32.13	< 0.0009
FEB	28,511	1018	1342	1.33	2.55	0.70	2.02	4.00	4.00	372	0.12	0.18	0.27	0.42	1.40	1.70	361	0.12	0.35	-	-	-
MAR	29,920	965	1223	1.38	2.37	1.01	2.00	4.60	4.60	330	0.16	0.19	0.26	0.35	2.00	2.00	329	0.06	0.09	-	-	-
APR	31,287	1043	1266	0.83	3.60	0.79	1.79	3.30	5.60	169	0.11	0.13	0.35	0.53	1.60	1.70	161	0.03	0.04	27.00	26.80	< 0.0009
MAY	38373	1238	1571	0.85	2.87	0.30	2.63	6.90	6.90	222	0.13	0.19	0.48	0.77	2.00	2.00	218	0.03	0.05	-	-	-
JUN	39275	1309	1879	1.50	2.37	0.66	2.33	3.30	3.30	275	0.31	0.88	1.04	4.43	1.60	1.60	281	0.11	0.55	-	-	-
JUL	39232	1266	1988	0.73	3.10	0.58	2.40	5.20	5.20	274	0.62	1.22	4.06	13.20	1.00	1.00	271	0.39	1.00	147.00	119.00	0.0024
AUG	36194	1168	1449	1.00	2.96	0.30	2.45	5.90	5.90	245	0.11	0.17	0.41	0.50	3.10	3.10	248	0.03	0.07	-	-	-
SEP	37708	1257	1524	0.97	3.26	0.46	2.06	8.50	8.50	308	0.20	0.53	0.45	0.73	4.40	4.40	287	0.03	0.06	-	-	-
OCT	36609	1181	1851	0.99	2.85	0.54	2.07	1.80	6.70	323	0.12	0.16	0.42	0.59	0.20	1.50	321	0.04	0.07	90.00	28.30	< 0.0009
NOV	34467	1149	1442	1.02	2.65	0.54	2.18	6.70	6.70	333	0.09	0.10	0.34	0.42	4.70	4.70	329	0.04	0.06	-	-	-
DEC																						
TOTAL	382,150																					
AVG		1,144						5.32	5.98	281	0.19		0.75		2.27	2.45	275	0.09		79.44	51.56	0.0009
MAX			1,988		3.60		2.63					1.22		13.20				1.00				
MIN				0.73		0.30																
CRITERIA			3,182	CT		0.25	3.00													<100	<80	<0.009

MONTH	SYSTEM FLOWS (RAW)			ACTIFLO FILTER #1		ACTIFLO FILTER #2		Efficiency		TANK		TREATED				E. coli / Total Coliform / HPC (Number of Samples Collected)				RAW WATER			
	Total Flow (m ³)	Avg. Day Flow (m ³)	Max. Flow (m ³)	Max. Flow Rate (L/min)	Avg. Turbidity (NTU)	Max. Turbidity (NTU)	Avg. Turbidity (NTU)	Max. Turbidity (NTU)	Turbidity % < 0.3 NTU Filter #1	Turbidity % < 0.3 NTU Filter #2	Backwash TSS (mg/L)	Supernatant TSS (mg/L)	OL Avg. Turbidity (NTU)	OL Max. Turbidity (NTU)	Min UV Intensity (mJ/cm ²)	Min UVT (%)	Safe		Adverse		Max. Coliform Count	Max. E.coli Count	
																		Treated	Distribution	Treated	Distribution		
JAN	38,963	1257	1790	2195	0.14	0.56	0.08	0.84	99.71	99.71	11	3	0.44	0.90	70	81	5	15	0	0	16,200	66	
FEB	38,499	1375	1666	2149	0.15	0.34	0.10	0.29	99.97	99.97	3	6	-	-	65	87	4	12	0	0	1,860	85	
MAR	38,816	1252	1606	2016	0.16	0.72	0.11	0.38	98.93	98.93	3	5	-	-	82	86	4	12	0	0	780	76	
APR	39,411	1314	1963	2086	0.18	0.81	0.14	0.71	97.00	98.39	3	11	-	-	96	86	4	12	0	0	19,600	45	
MAY	45,286	1461	1750	2021	0.21	0.83	0.15	0.71	92.56	97.25	14	9	-	-	63	85	5	15	0	0	2,400	152	
JUN	44,165	1472	2317	2171	0.28	0.93	0.20	0.86	71.41	90.61	12	9	0.90	3.70	81	86	4	12	0	0	50	14	
JUL	47,573	1535	2070	2215	0.35	0.86	0.38	0.98	50.56	63.44	15	7	2.83	5.00	73	87	5	16	0	0	20,000	290	
AUG	41,731	1346	1844	1993	0.15	0.80	0.19	0.68	98.96	96.84	10	4	0.29	1.55	75	72	4	12	0	0	110	26	
SEP	42,782	1426	1737	1970	0.18	0.90	0.24	0.68	94.45	90.74	15	6	0.33	0.69	68	69	4	12	0	0	150	12	
OCT	42,127	1359	1919	1925	0.17	0.73	0.22	0.62	95.72	91.81	15	8	0.30	0.70	66	74	5	15	0	0	160	43	
NOV	40,414	1347	1648	2070	0.19	0.95	0.22	0.49	99.36	98.04	13	4	0.24	2.25	55	70	4	12	0	0	1,600	52	
DEC																							
TOTAL	459,766																48	145	0	0			
AVG		1,377			0.20		0.18		90.78	93.25	10.4	6.5	0.76										
MAX			2,317	2,215		0.95		0.98			15	11		5.00							20,000	290	
MIN															55.00	69.00							
CRITERIA			3,182	2,205		<1		<1	>95%	>95%	<25	<25		<5	>40								

COMMENTS: * Treated Water OL Turbidity - No reliable readings trended on SCADA from January 20th - 31th, February, March, April, May, June 1 to June 14th 2023
 ** Added Individual Filter Efficiency Tracking in April 2023
 *** Raw Water Flow Rate Spike above 2205 L/min on July 17, 2023 for less than 1 minute.

**ONTARIO CLEAN WATER AGENCY
PERFORMANCE ASSESSMENT REPORT**

OWNER: MUNICIPALITY OF CASSELMAN
PROJECT: CASSELMAN WASTEWATER TREATMENT SYSTEM
ECA NUM.: 8160-BAHPRF
DESCRIPTION: MOVING BED BIOLOGICAL REACTOR (MBBR) TREATMENT LAGOON

YEAR: 2023
WATER COURSE: NATION RIVER
DESIGN CAPACITY: 2,110 m³/d
FACILITY WORKS#: 110002201

MONTH	RAW								EFFLUENT										
	Total Flow m ³	Avg Day Flow m ³	Max Day Flow m ³ /d	Avg Alum Dosage (mg/L)	Avg Raw BOD5 (mg/L)	Avg Raw TSS (mg/L)	Avg. Raw TKN (mg/L)	Avg Raw TP (mg/L)	Effluent Flow m ³	Effluent Avg Flow m ³	Effluent Max Flow m ³ /d	Avg CBOD5 (mg/L)	Avg TSS (mg/L)	Avg TAN (mg/L)	Avg TP (mg/L)	Avg TKN (mg/L)	Avg Nitrate (mg/L)	Avg Nitrite (mg/L)	E. coli (cfu/100 mL)
JAN	48,260	1,557	2,167	175	167	240	36.8	4.10	131,702	4,248	4,906	7.6	12.0	15.8	0.36	19.5	7.1	0.09	2717
FEB	45,524	1,626	1,948	192	500	660	82.0	9.14	56,404	2,014	2,344	4.3	10.3	11.1	0.47	14.2	18.5	0.12	738
MAR	61,249	1,976	2,888	188	294	480	52.0	6.29	60,153	1,940	3,458	4.0	8.0	0.91	0.36	2.62	29.1	0.07	598
APR	69,141	2,305	3,316	191	97	156	33.3	3.73	106,114	3,790	4,734	3.3	5.8	0.72	0.51	2.38	15.8	0.07	20
MAY	47,919	1,546	2,216	163	329	850	33.4	6.42	33,643	4,205	4,977	3.0	5.0	0.08	0.44	1.35	10.2	0.05	2
JUN	36,924	1,231	1,289	92	293	590	86.0	9.22											
JUL	48,167	1,554	1,688	127	439	630	49.3	7.24											
AUG	44,749	1,444	1,636	84	266	988	32.0	4.06											
SEPT	36,022	1,201	1,317	85	220	330	50.8	5.17											
OCT	37,523	1,210	1,254	64	341	630	124.0	11.40	60,800	2,252	2,456	3.0	3.8	0.07	0.09	1.20	0.8	0.05	12
NOV	38,462	1,282	1,344	73	426	880	82.4	9.95	65,334	2,178	2,406	3.0	3.3	0.35	0.08	1.8	1.1	0.06	3
DEC																			
TOTAL	513,940								514,150										
AVG		1,539		130	307	585	60	6.97		2,947		4.0	6.9	4.2	0.33	6.16	11.8	0.07	56
MAX			3,316		500	988	124	11.40			4,977	7.6	12.0	15.8	0.51	19.54	29.1	0.12	2,717
CRITERIA						Fall Discharge			267,650	2,909									
A						Winter/Spring Dircharge			502,500	3,722	5,000								

COMPLIANCE											YES								
-------------------	--	--	--	--	--	--	--	--	--	--	------------	--	--	--	--	--	--	--	--

MONTH	UPSTREAM*				DOWNSTREAM**			
	Avg CBOD5 (mg/L)	Avg TSS (mg/L)	Avg TAN (mg/L)	Avg PHOS. (mg/L)	Avg CBOD5 (mg/L)	Avg TSS (mg/L)	Avg TAN (mg/L)	Avg PHOS. (mg/L)
JAN	3.0	17.0	0.10	0.08	-	-	-	-
FEB	-	-	-	-	-	-	-	-
MAR	-	-	-	-	-	-	-	-
APR	3.3	75.0	0.35	0.22	2.75	19.0	0.20	0.10
MAY	3.0	17.5	0.05	0.11	3.0	78.5	0.05	0.09
JUN								
JUL								
AUG								
SEPT								
OCT	3.0	8.6	0.19	0.07	3.0	12.6	0.16	0.07
NOV	3.0	8.5	0.26	0.08	3.0	8.5	0.18	0.06
DEC								
TOTAL								
AVG	3.1	25	0.19	0.11	2.9	29.7	0.15	0.08
MAX	3.25	75	0.35	0.22	3.0	78.5	0.20	0.10
CRITERIA								

COMPLIANCE																			
-------------------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

Comments:

*No Upstream Samples required to be collected when downstream sampling is not feasible (January 31, February, March)

**No Downstream samples were taken due to ice cover on the Nation River (January, February, March)

Appendix B

Work Order Summary Reports



Monthly Work Order Summary – November 2023

Casselman Drinking Water System

Description	Status	Work Type
Analyzer Total Chlorine Inspection/Service (1m) 5971	COMP	PM
Analyzer pH Inspection/Service (1m) 5971	COMP	PM
Analyzer Spectrophotometer Insp/Service (1m) - 5971	COMP	PM
Analyzer Turbidity Inspection/Service (1m) 5971	COMP	PM
Blower Centrifugal Inspection/Service (1m) 5971	COMP	PM
Air Compressor Inspection/Service (1m) 5971	COMP	PM
Dryer Air Service (1m) - 5971	COMP	PM
Generator Inspection (1m) 5971	COMP	PM
Weight Scale Calibration (1y) 5971	APPR	PM
PANEL ALARM/DIALER TEST (1m) - 5971	COMP	PM
Pump Vertical Turbine Lo Lift 101 Insp/Service (1y) 5971	APPR	PM
Pump Centrifugal 02 UV Room Inspection/Service (1y) 5971	COMP	PM
UV Light Bank Insp/Service (1m) - 5971	COMP	PM
Monthly H&S Equipment Check (1m) - 5971	COMP	PM
Client Reports (1m) - Casselman 5971	COMP	PM
UVT Sensor Checks/Calibration (1m) - 5971	COMP	PM
Pump Diaphragm Coagulant Route Inspection/Service (1m) 5971	COMP	PM
Pump Diaphragm Polymer Route Inspection/Service (1m) 5971	COMP	PM
Pump Diaphragm Sodium Hydroxide Route Inspection/Service (1m) 5971	COMP	PM
Pump Diaphragm Ammonium Sulphate Route Inspection/Service (1m) 5971	COMP	PM
Pump Diaphragm Potassium Permanganate Route Inspection/Service (1m) 5971	COMP	PM
Analyzer Turbidity Inspection/Service (1m) 1501	COMP	PM
WISKI Monthly Review(1m) 5971	COMP	PM
Meter Flow Casselman WTP Calibration (1y) 5971	COMP	PM
UV Sensor Reference Check/Calibration (1m) - 5971	COMP	PM
Workplace Inspection (1m) - 5971	COMP	OPER
O&M - Casselman - 5971 - WTP - HACH Equipment Calibrations	COMP	OPER
Capital - Casselman Wtp - 5971 - Raw Water pump Lab	COMP	CORR
Budget VFD's Casselman WTP 5971	APPR	CAP
Capital UPS batteries Casselman WTP 5971	COMP	CAP
Casselman - 1553 - WD - Turn On Water Service - 300 A/B Zachary St	COMP	CAP
Casselman - 1553 - WD - Turn On Water Service - 302 A/B Zachary St	COMP	CAP
Casselman - 1553 - WD - Turn On Water Service - 305 Zachary St	COMP	CAP
Captial - Casselman - 1553 - WD - Standpost repair - 34 Desnoyers	COMP	CAP
Casselman - 5971 - WTP - Actiflo2 Pressure Differential	COMP	CALL
Call Back - Casselman - 5971 - WTP - Back to back backwashes for filters	COMP	CALL
Call Back - Casselman - 5971 - WTP - Back to back backwashes and chlorine breakpoint issues	COMP	CALL
Call Back - Casselman WTP - 5971 - Actiflo #2 Recirculation Pump Fault	COMP	CALL
Casselman 5971 Actiflo 2 Backwash process	COMP	CALL
Casselman 5971 Actiflo 1 Backwash process	COMP	CALL

Monthly Work Order Summary – November 2023
Casselman Drinking Water System

Casselman - 5971 - WTP - Actiflo2 Pressure Differential	COMP	CALL
Casselman - 5971 - WTP - Actiflo2 Pressure Differential	COMP	CALL
Casselman - 5971 - WTP - Actiflo2 Pressure Differential	COMP	CALL
AWQI - Filter 2 - 95 % Efficiency - October - 5971	COMP	ADMIN

Monthly Work Order Summary – November 2023
Casselman Wastewater Treatment & Collection System

Description	Status	Work Type
Generator Inspection (1m) SPS #1 1501	COMP	PM
Generator Inspection (1m) SPS #2 1501	COMP	PM
Generator Inspection (1m) SPS #3 1501	COMP	PM
Generator Inspection (1m) SPS #5 1501	COMP	PM
Generator Inspection (1m) SPS #6 1501	COMP	PM
Generator Inspection (1m) 1501	COMP	PM
Analyzer Turbidity Inspection/Service (1m) 1501	COMP	PM
PANEL ALARM/DIALER TEST (1m) 1501	COMP	PM
Monthly H&S Equipment Check (1m) - 1501	COMP	PM
Blower Inspection/Service (1m/1y) 1501	COMP	PM
Blower Inspection/Service (1m/1y) 1501	COMP	PM
Blower Inspection/Service (1m/1y) 1501	COMP	PM
Blower Inspection/Service (1m/1y) 1501	COMP	PM
Blower Inspection/Service (1m/1y) 1501	COMP	PM
Blower Inspection/Service (1m/1y) 1501	COMP	PM
Bar Screen Inspection (1m) 1501	COMP	PM
PANEL ALARM/DIALER TEST (1m) - 1501	COMP	PM
PANEL ALARM/DIALER TEST (1m) - 1501	COMP	PM
PANEL ALARM/DIALER TEST (1m) - 1501	COMP	PM
PANEL ALARM/DIALER TEST (1m) - 1501	COMP	PM
PANEL ALARM/DIALER TEST (1m) - 1501	COMP	PM
PANEL ALARM/DIALER TEST (1m) - 1501	COMP	PM
PANEL ALARM/DIALER TEST (1m) - 1501	COMP	PM
PANEL ALARM/DIALER TEST (1m) - 1501	COMP	PM
WISKI Monthly Review(1m) 1501	COMP	PM
Workplace Inspection (1m) - 1501	COMP	OPER
O&M - Casselman - 1501 - WW - HACH Equipment Calibrations	COMP	OPER
Casselman - WWT - 1501 - Cleaning SPS 1, 5 and cell #2 of MBBR	COMP	OPER
Budget Wet Well Repairs Casselman Sewage 1501	APPR	CAP
Call Back - Casselman - 1501 - Sewage - Power Outage Stations reset	COMP	CALL

Appendix C

Locate Summary



Casselman Monthly Locate Summary – November 2023

Description	Status	Work Type
Locate Casselman WDS 1553 - 20234112440 - Racine and Industriel	COMP	OPER
Locate Casselman WDS 1553 - 20234512519 - 614 Laurier St	COMP	OPER
Locate Casselman WDS 1553 - 20234513345 - 369 Dore St	COMP	OPER
Locate Casselman WDS 1553 - 20234516907 - 876 Laval St	COMP	OPER
Locate Casselman WDS 1553 - 20234516927 - 676 ST Isidore	COMP	OPER
Locate Casselman WDS 1553 - 20234516940 - 688 St Isidore	COMP	OPER
Locate Casselman WDS 1553 - 20234516990 - 726 St Isidore	COMP	OPER
Locate Casselman WDS 1553 - 20234516999 - 740 St Isidore	COMP	OPER
Locate Casselman WDS 1553 - 20234517007 - 800 St Isidore	COMP	OPER
Locate Casselman WDS 1553 - 20234518433 - 759 St Joseph	COMP	OPER
Locate Casselman WDS 1553 - 2023454393 - 57 Isabelle	COMP	OPER
Locate Casselman WDS 1553 - 2023455501 - 300 - 302 Zakari St	COMP	OPER
Locate Casselman WDS 1553 - 2023456571 - Racine and Industriel	COMP	OPER
Locate Casselman WDS 1553 - 2023457137 - 778 Brebeuf St	COMP	OPER
Locate Casselman WDS 1553 - 2023459138 - 305 Zakari St	COMP	OPER
Locate Casselman WDS 1553 - 2023459855 - Zakari St	COMP	OPER
Locate Casselman WDS 1553 - 20234610862 - 710 St Isidore	COMP	OPER
Locate Casselman WDS 1553 - 20234611734 - 567 St Isidore	COMP	OPER
Locate Casselman WDS 1553 - 20234615165 - 745 Brebeuf St	COMP	OPER
Locate Casselman WDS 1553 - 2023468653 - 18 Sarah St	COMP	OPER
Locate Casselman WDS 1553 - 20234411185 - Lafontaine Sideroad Pond	COMP	CAP
Locate Casselman WDS 1553 - 20234416883 - Racine and Industriel	COMP	CAP
Locate Casselman WDS 1553 - 20234417084 - 862 to 858 Principale	COMP	CAP
Locate Casselman WDS 1553 - 20234417335 - Maria and Argile	COMP	CAP
Locate Casselman WDS 1553 - 2023445343 - 724 to 720 St Joseph	COMP	CAP
Locate Casselman WDS 1553 - 2023446590 - HWY 417	COMP	CAP
Locate Casselman WDS 1553 - 2023448092 - HWY 417	COMP	CAP
Locate Casselman WDS 1553 - 2023448379 - St Isidore	COMP	CAP
Locate Casselman WDS 1553 - 20234610852 - St Isidore and Laval	COMP	CAP
Locate Casselman WDS 1553 - 20234610857 - 707 St Isidore	COMP	CAP
Locate Casselman WDS 1553 - 20234616970 - 872 Pricipale St	COMP	CAP
Locate Casselman WDS 1553 - 2023465287 - Brisson St	COMP	CAP
Locate Casselman WDS 1553 - 20234710849 - 2 Sauve Terrace	COMP	CAP
Locate Casselman WDS 1553 - 20234712391 - 615 St Isidore	COMP	CAP
Locate Casselman WDS 1553 - 20234712527 - River Nation Rd	COMP	CAP
Locate Casselman WDS 1553 - 2023476643 - 685 Duhamel St	COMP	CAP
Locate Casselman WDS 1553 - 2023477160 - Racine St	COMP	CAP
Locate Casselman WDS 1553 - 2023477828 - 633 to 613 Conservation St	COMP	CAP
Locate Casselman WDS 1553 - 2023478493 - St Therese	COMP	CAP
Locate Casselman WDS 1553 - 2023481049 - 16 Albert St	COMP	CAP
Locate Casselman WDS 1553 - 2023482951 - HWY 417	COMP	CAP
Locate Casselman WDS 1553 - 2023487120 - 8 Racine St	COMP	CAP
Locate Casselman WDS 1553 - 2023488293 - 825 Principale St	COMP	CAP
Locate Casselman WDS 1553 - 2023488975 - 300 - 302 Zakari St	COMP	CAP
Locate Casselman WDS 1553 - 2023488984 - 305 Zakari St	COMP	CAP
Total		45